

CAPE MAY COUNTY MUNICIPAL UTILITIES AUTHORITY
1523 Route 9 North
Cape May Court House, NJ 08210
Phone: (609) 465-9026 Fax: (609) 465-9025

ADDENDUM NO. 1
to the
CONTRACT DOCUMENTS

FURNISH AND DELIVER DRY POLYMER TO
VARIOUS CMCMUA WASTEWATER TREATMENT FACILITIES

CONTRACT CHEM-56-21

To All Document Holders:

The following changes, additions and/or deletions are hereby made a part of the Contract Documents for the above referenced contract as fully and completely as if the same were fully set forth herein:

TECHNICAL SPECIFICATIONS - SECTION IV

1. In Section 2.0 Polymers for Sludge Dewatering, the following is added:

2.6 Equivalent Products

To qualify as an equivalent product, the bidder must submit a Safety Data Sheet (SDS) and all other technical documentation on the proposed product with the bid proposal. Specifically, the SDS must describe the product being in "bead" form to be considered equivalent.

If the bidder is deemed the apparent low bidder and proves to be technically equivalent based on the SDS, the bidder must full scale test product equivalency within 10 business days from notification of status. To prove equivalency, the product must be full scale tested at all three CMCMUA wastewater treatment facilities, at the expense of the bidder. The bidder shall supply, one (1), fifty-five (55) pound container of product to each of the CMCMUA wastewater treatment facilities for this testing (i.e total of three (3) containers), adhering to the requirements of the Technical Specifications, Page IV-2, 1.5 Packaging. The following performance specifications must all be met at all three (3) wastewater treatment facilities:

- Cake-38%
- Capture rate-90%
- lbs/dry ton- 11

If the product does not meet the specified performance requirements, it shall be deemed as not equivalent and the bid will be determined to be non-responsive.

All bidders shall acknowledge the receipt and acceptance of this Addendum No. 1 by indicating Addendum Number in the space provided on the Acknowledgement of Receipt of Addenda Form. Bids submitted without this Addendum Acknowledgement will be considered non-responsive.