

CAPE MAY COUNTY MUNICIPAL UTILITIES AUTHORITY  
1523 Route 9 North  
Cape May Court House, NJ 08210  
Phone: (609) 465-9026 Fax: (609) 465-9025

ADDENDUM NO. 2  
to the  
CONTRACT DOCUMENTS  
NEW ELECTRICAL SYSTEMS FOR  
VARIOUS PUMP STATIONS  
CONTRACT WW-EQUIP-02-20

---

To All Document Holders:

The following changes, additions and/or deletions are hereby made a part of the Contract Documents for the above referenced contract as fully and completely as if the same were fully set forth herein:

**DRAWINGS**

1. Drawing No. M101, Details 1 & 2:  
Drawing No. M201, Details 1 & 2:  
Drawing No. M301, Details 1 & 2:  
Drawing No. M401, Details 1 & 2:

Change

“NEW EXHAUST PIPE, SS, SCH 40, SEE NOTE 1”

To

“NEW EXHAUST PIPE, BLACK STEEL, SCH 40, SEE NOTE 1”

2. Drawing No. MJ102, General Note 3:

Change

“<sup>3</sup>/<sub>4</sub>” BLACK STEEL FUEL LINES”

To

“1” BLACK STEEL FUEL LINES”

**SPECIFICATIONS**

1. Section 010100 – SUMMARY OF WORK:

Paragraph 1.2.A.4, Add the sentence:

“Should temporary generators be used in lieu of bypass pumping, the Contractor must provide both a primary generator and a back-up generator as sources of power.”

2. Section 015400 – BYPASS PUMPING SYSTEM:

2.1 Paragraph 1.1.A:

Delete the phrase:

“shown on the contract drawings and”

2.2 Paragraph 1.2.A:  
Start with the added sentence:

“The Plan and Bypass Sketches shown on the contract drawings are for the Contractor’s information only.”

2.3 Paragraph 1.6.B.1  
Delete the phrase:

“shown on the Contract Drawings and”

3. Section 263600 – TRANSFER SWITCHES:

3.1 Paragraph 1.1.A:  
Add the subparagraph:

“2. In existing MCCs, where transfer switches are to be replaced, the existing MCC UL listing shall not be required to be maintained.”

3.2 Paragraph 2.2.E.  
Add the subparagraph:

“9. Existing Transfer Switches Internal Connections: All existing internal connections are cable, with the exception of the 39<sup>th</sup> Street Pump Station, where the main breaker line and common load connection are bus connected.”

**All bidders shall acknowledge the receipt and acceptance of this Addendum No. 2 by indicating Addendum Number in the space provided on the Acknowledgement of Receipt of Agenda Form. Bids submitted without this Addendum acknowledgement will be considered non-responsive.**