

CAPE MAY COUNTY MUNICIPAL UTILITIES AUTHORITY  
1523 Route 9 North  
Cape May Court House, NJ 08210  
Phone: (609) 465-9026 Fax: (609) 465-9025

ADDENDUM NO. 1  
to the  
CONTRACT DOCUMENTS

SECURE SANITARY LANDFILL  
LEACHATE PUMP STATIONS  
CONTROL/POWER REPLACEMENT

CONTRACT SLF-03-23

---

To All Document Holders:

The following changes, additions and/or deletions are hereby made a part of the Contract Documents for the above referenced contract as fully and completely as if the same were fully set forth herein:

**DRAWINGS**

1. On Drawing No. E-123, Detail No, 2, change the reference from Key Note 5 to Key Note 2.
2. On Drawing No, E-124, Delete Key Note 5, as written, and replace with the following:  
  
"5. NEW FIBER CABLE TO BE RUN IN 3 DIRECTIONS (FROM POLE SLF-T-19 TO AND FROM POLE SLF-T-21, AND THEN TO POLE SLF-T-25). SEE DETAILS ON SHEET E-506 FOR FIBER CABLE INSTALLATION ON EXISTING POLES. FIBER RUNS IN MULTIPLE DIRECTIONS AS HEREIN DESCRIBED SHALL HAVE MORE THAN A SINGLE CLAMP."
3. On Drawing No. E-606, change the reference given in General Note 1 from SECTION 269100 to SECTION 250201.

**All bidders shall acknowledge the receipt and acceptance of this Addendum No. 1 by indicating Addendum Number in the space provided on the Acknowledgement of Receipt of Addenda Form. Bids submitted without this Addendum Acknowledgement will be considered non-responsive.**