CAPE MAY COUNTY MUNICIPAL UTILITIES AUTHORITY 1523 Route 9 North

Cape May Court House, NJ 08210 Phone: (609) 465-9026 Fax: (609) 465-9025

ADDENDUM NO. 1 to the CONTRACT DOCUMENTS

FURNISH AND DELIVER PETROLEUM OIL AND LUBRICANT PRODUCTS

CONTRACT MUA-EQUIP-54-21

To All Document Holders:

The following changes, additions and/or deletions are hereby made a part of the Contract Documents for the above referenced contract as fully and completely as if the same were set forth herein:

The following replaces Part D in SECTION IV, Page IV-1, 2.0 of the Technical Specifications.

Part D: Landfill Gas Powered Generator Motor Oil:

The proposed Petroleum Oil Product must be listed as an approved motor oil by Jenbacher Innio for use in a Type 3, Class C electrical generating engine with a sulfated ash content of less than 0.6%. Acceptable lubricating oil products listed by Jenbacher Innio for use in the electrical generating engines that meet these requirements are as follows;

- Addinol Gas Engine Oil LG 40
- Cepsa Troncoil Biogas Low Ash
- Fuchs Titan Ganymet
- Fuchs Titan Ganymet PRO MA
- Mobil Pegasus 605 Ultra
- MOL GMO Long Life
- Morris Lubricants GEO Ultra G-LF 40
- Morris Lubricants GEO Ultra LZ 40
- Motul Cressida
- Petro Canada Sentron CG 40 plus
- Petronas GEO BLG
- Q8 Oils Mahler G5
- Repsol Long Life Biogas 4005
- Shell Mysella S5S
- Shell Mysella S6 SM
- Texaco Chevron Caltex HDAX 6500 LFG Gas Engine Oil 40
- Valvoline GEO SLF SAE 40
- Valvoline GEO Plus LA Engine Oil SAE 40

Addendum No. 1 Page 1 of 2

The following replaces Part F in SECTION IV, Page IV-2, 2.0 of the Technical Specifications.

Part F: Ethylene Glycol:

The proposed Ethylene Glycol Product must be listed as an approved antifreeze by Jenbacher Innio for use in a Type 3, Class C electrical generating engine and have a 50/50 mixture ratio. Acceptable anti-freeze products listed by Jenbacher Innio for use in the electrical generating engines that meet these requirements are as follows;

- Arteco Havoline XLC 50/50
- Texaco Chevron Caltex Delo XLC Antifreeze/Coolant-Premixed 50/50

All bidders shall acknowledge the receipt and acceptance of this Addendum No. 1 by indicating the Addendum Number in the space provided on the Acknowledgement of Receipt of Addenda Form. Bids submitted without this Addendum Acknowledgement will be considered non-responsive.

Addendum No. 1 Page 2 of 2